

Statement of Conformity with AS/NZS 3003:2018

- ☐ Cardiac-protected electrical area
☐ Body-protected electrical area
☐ Repair to electrical installation

- ☐ New patient area
☐ Alteration or addition to electrical installation

Institution	
Address	
Location	
Description of electrical work	
Date completed	Date of statement

I, the licensed electrical installation worker, who carried out the work described above, certify that:

The work has passed all the required tests and complies in all respects with the current edition of AS/NZS 3000.	☐ Yes	☐ No	☐ N/A
The work has followed a formal specification prepared by or on behalf of the health care institution or practice.	☐ Yes	☐ No	☐ N/A
I/ We have discussed the number of socket-outlets required with the medical or nursing personnel who will be responsible for work in each area and verified the likely loading on each circuit.	☐ Yes	☐ No	☐ N/A
I/We have verified that the isolation transformer, line isolation monitor and overload monitor comply with AS/NZS 4510.	☐ Yes	☐ No	☐ N/A
I/We are in possession of manufacturers' statement(s) of compliance or have otherwise verified that each ELV supply conforms with a suitable standard ensuring double insulation from the LV supplies.	☐ Yes	☐ No	☐ N/A
Scope of works Customer Acceptance The customer acknowledges and agrees that Electrical Testing Co has been engaged to: • Provide Inspection, testing and reporting of Electrical installations in Patient Areas in accordance with the requirements of AS3003:2018; • Provide accredited (NATA) endorsement of testing and non accredited (independent) inspection activities as part of the engaged scope. • Have reviewed our standard terms and conditions available on our website or alternatively where both parties have entered into a contract (major projects only).			☐ Yes
Decision Rule Accepted by Customer The customer acknowledges and agrees that where a statement of conformity is requested, the laboratory will apply the following decision rule: • results with measured deviation less than 2.5% from the specified acceptance criterion shall be reported as Pass; • results with measured deviation greater than 2.5% from the specified acceptance criterion shall be reported as Fail. The customer acknowledges that this decision rule will be used by the laboratory for conformity assessment and reporting of results.			☐ Yes

Name	
Company	
Address	
Signed	Electrical licence number